



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

Account #: 13407

Tim Harbo
Madelia Public School
320 Buck Ave SE
Madelia, MN 56062

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:

Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

Workorder Summary

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM

Page 2 of 17

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
 www.MVTL.com

**Workorder:** Elementary (13968)**Client:** Madelia Public School**Analytical Results**

Lab ID:	13968001	Date Collected:	04/28/2023 05:20	Matrix:	Potable Water		
Sample ID:	1-EL-Room 103	Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Parameter		Results	Units	MCL	Method	Analyzed	Qual
Lead		2.20	ug/L	15	EPA 200.8	05/10/2023 23:18	
Lab ID:	13968002	Date Collected:	04/28/2023 05:20	Matrix:	Potable Water		
Sample ID:	2-EL-Room 104	Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Parameter		Results	Units	MCL	Method	Analyzed	Qual
Lead		2.25	ug/L	15	EPA 200.8	05/10/2023 23:19	
Lab ID:	13968003	Date Collected:	04/28/2023 05:20	Matrix:	Potable Water		
Sample ID:	3-EL-Room 105	Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Parameter		Results	Units	MCL	Method	Analyzed	Qual
Lead		0.56	ug/L	15	EPA 200.8	05/10/2023 23:21	
Lab ID:	13968004	Date Collected:	04/28/2023 05:20	Matrix:	Potable Water		
Sample ID:	4-EL-DF across from 105	Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Parameter		Results	Units	MCL	Method	Analyzed	Qual
Lead		1.57	ug/L	15	EPA 200.8	05/10/2023 23:22	
Lab ID:	13968005	Date Collected:	04/28/2023 05:20	Matrix:	Potable Water		
Sample ID:	5-EL-Room 102	Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Parameter		Results	Units	MCL	Method	Analyzed	Qual
Lead		3.65	ug/L	15	EPA 200.8	05/10/2023 23:23	
Lab ID:	13968006	Date Collected:	04/28/2023 05:20	Matrix:	Potable Water		
Sample ID:	6-EL-Room 106	Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Parameter		Results	Units	MCL	Method	Analyzed	Qual
Lead		0.76	ug/L	15	EPA 200.8	05/10/2023 23:24	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
 www.MVTL.com

**Workorder:** Elementary (13968)**Client:** Madelia Public School**Analytical Results**

Lab ID: 13968007 **Date Collected:** 04/28/2023 05:20 **Matrix:** Potable Water
Sample ID: 7-EL-Room 106 Bathroom **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/10/2023 23:26	

Lab ID: 13968008 **Date Collected:** 04/28/2023 05:20 **Matrix:** Potable Water
Sample ID: 8-EL-Room 107 **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.76	ug/L	15	EPA 200.8	05/10/2023 23:27	

Lab ID: 13968009 **Date Collected:** 04/28/2023 05:20 **Matrix:** Potable Water
Sample ID: 9-EL-Room 108 **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/10/2023 23:28	

Lab ID: 13968010 **Date Collected:** 04/28/2023 05:20 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 10-EL-Room 109

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.52	ug/L	15	EPA 200.8	05/10/2023 23:30	

Lab ID: 13968011 **Date Collected:** 04/28/2023 05:20 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 11-EL-Room 110

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.59	ug/L	15	EPA 200.8	05/10/2023 23:40	

Lab ID: 13968012 **Date Collected:** 04/28/2023 05:30 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 12-EL-Room 111

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.41	ug/L	15	EPA 200.8	05/10/2023 23:41	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
 www.MVTL.com

**Workorder:** Elementary (13968)**Client:** Madelia Public School**Analytical Results**

Lab ID: 13968013 **Date Collected:** 04/28/2023 05:30 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 13-EL-Room 111 Bathroom

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.99	ug/L	15	EPA 200.8	05/10/2023 23:42	

Lab ID: 13968014 **Date Collected:** 04/28/2023 05:30 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 14-EL-Media 113 Storage

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.74	ug/L	15	EPA 200.8	05/10/2023 23:44	

Lab ID: 13968015 **Date Collected:** 04/28/2023 05:30 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 15-EL-Gally Right Sink

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.84	ug/L	15	EPA 200.8	05/10/2023 23:45	

Lab ID: 13968016 **Date Collected:** 04/28/2023 05:30 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 16-EL-Gally Left Sink

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.74	ug/L	15	EPA 200.8	05/10/2023 23:46	

Lab ID: 13968017 **Date Collected:** 04/28/2023 05:30 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 17-EL-Cafeteria BF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/10/2023 23:47	

Lab ID: 13968018 **Date Collected:** 04/28/2023 05:30 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 18-EL-Cafeteria DF-Left

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/10/2023 23:49	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
 www.MVTL.com

**Workorder:** Elementary (13968)**Client:** Madelia Public School**Analytical Results**

Lab ID:	13968019	Date Collected:	04/28/2023 05:30	Matrix:	Potable Water		
Sample ID:		Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Sample Desc:	19-EL Cafeteria DF-Right						
Parameter	Results	Units	MCL	Method	Analyzed	Qual	
Lead	<0.5	ug/L	15	EPA 200.8	05/10/2023 23:50		
Lab ID:	13968020	Date Collected:	04/28/2023 05:30	Matrix:	Potable Water		
Sample ID:		Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Sample Desc:	20-EL-Kitchen prep sink sprayer						
Parameter	Results	Units	MCL	Method	Analyzed	Qual	
Lead	0.98	ug/L	15	EPA 200.8	05/10/2023 23:51		
Lab ID:	13968021	Date Collected:	04/28/2023 05:30	Matrix:	Potable Water		
Sample ID:		Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Sample Desc:	21-EL-Kitchen Chop Sink Faucet						
Parameter	Results	Units	MCL	Method	Analyzed	Qual	
Lead	1.07	ug/L	15	EPA 200.8	05/11/2023 00:02		
Lab ID:	13968022	Date Collected:	04/28/2023 05:30	Matrix:	Potable Water		
Sample ID:		Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Sample Desc:	22-EL-Kitchen Steam Kettle						
Parameter	Results	Units	MCL	Method	Analyzed	Qual	
Lead	2.43	ug/L	15	EPA 200.8	05/11/2023 00:03		
Lab ID:	13968023	Date Collected:	04/28/2023 05:40	Matrix:	Potable Water		
Sample ID:		Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Sample Desc:	23-EL-Nurses Office Sink						
Parameter	Results	Units	MCL	Method	Analyzed	Qual	
Lead	2.48	ug/L	15	EPA 200.8	05/11/2023 00:04		
Lab ID:	13968024	Date Collected:	04/28/2023 05:40	Matrix:	Potable Water		
Sample ID:		Date Received:	04/28/2023 07:35				
Temp @ Receipt (C):							
Sample Desc:	24-EL-Nurses Office Bathroom Sink						
Parameter	Results	Units	MCL	Method	Analyzed	Qual	
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 00:05		

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
 www.MVTL.com

**Workorder:** Elementary (13968)**Client:** Madelia Public School**Analytical Results**

Lab ID: 13968025 **Date Collected:** 04/28/2023 05:40 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 25-EL-Teacher Work Room

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.61	ug/L	15	EPA 200.8	05/11/2023 00:07	

Lab ID: 13968026 **Date Collected:** 04/28/2023 05:40 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 26-EL-Entry Hall DF-Left

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 00:08	

Lab ID: 13968027 **Date Collected:** 04/28/2023 05:40 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 27-EL-Entry Hall DF-Right

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 00:09	

Lab ID: 13968028 **Date Collected:** 04/28/2023 05:40 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 28-EL-Entry Hall BF-Right

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 00:10	

Lab ID: 13968029 **Date Collected:** 04/28/2023 05:40 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 29-EL-DF across from 119

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.74	ug/L	15	EPA 200.8	05/11/2023 00:12	

Lab ID: 13968030 **Date Collected:** 04/28/2023 05:40 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 30-EL-Room 119

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.80	ug/L	15	EPA 200.8	05/11/2023 00:13	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

Analytical Results

Lab ID: 13968031 **Date Collected:** 04/28/2023 05:40 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 31-EL-Room 121

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.71	ug/L	15	EPA 200.8	05/11/2023 00:23	

Lab ID: 13968032 **Date Collected:** 04/28/2023 05:40 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 32-EL-Hall by Gym BF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 00:25	

Lab ID: 13968033 **Date Collected:** 04/28/2023 05:40 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 33-EL-Gym DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 00:26	

Lab ID: 13968034 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 34-EL-Auditorium Entrance DF

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	4.41	ug/L	15	EPA 200.8	05/11/2023 00:27	

Lab ID: 13968035 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 35-EL-Room 209

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.21	ug/L	15	EPA 200.8	05/11/2023 00:28	

Lab ID: 13968036 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 36-EL-Room 210

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.03	ug/L	15	EPA 200.8	05/11/2023 00:30	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

Analytical Results

Lab ID: 13968037 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 37-EL-Room 211

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.17	ug/L	15	EPA 200.8	05/11/2023 00:31	

Lab ID: 13968038 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 38-EL-Room 212

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.64	ug/L	15	EPA 200.8	05/11/2023 00:32	

Lab ID: 13968039 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 39-EL-Room 207

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.65	ug/L	15	EPA 200.8	05/11/2023 00:33	

Lab ID: 13968040 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 40-EL-Room 213

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.63	ug/L	15	EPA 200.8	05/11/2023 00:35	

Lab ID: 13968041 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 41-EL-Room 214

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.34	ug/L	15	EPA 200.8	05/11/2023 00:45	

Lab ID: 13968042 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 42-EL-Room 215

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.61	ug/L	15	EPA 200.8	05/11/2023 00:46	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
 www.MVTL.com

**Workorder:** Elementary (13968)**Client:** Madelia Public School**Analytical Results**

Lab ID: 13968043 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 43-EL-Room 216

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.96	ug/L	15	EPA 200.8	05/11/2023 00:48	

Lab ID: 13968044 **Date Collected:** 04/28/2023 05:50 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 44-EL-Upper Level BF by Elevator

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 00:49	

Lab ID: 13968045 **Date Collected:** 04/28/2023 06:00 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 45-EL-Upper Level DF by Elevator

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 00:50	

Lab ID: 13968046 **Date Collected:** 04/28/2023 06:00 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 46-EL-Room 217-Right Sink

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.90	ug/L	15	EPA 200.8	05/11/2023 00:51	

Lab ID: 13968047 **Date Collected:** 04/28/2023 06:00 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 47-EL-Room 217-Left Sink

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 00:53	

Lab ID: 13968048 **Date Collected:** 04/28/2023 06:00 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 48-EL-Room 219

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.63	ug/L	15	EPA 200.8	05/11/2023 00:54	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

Analytical Results

Lab ID: 13968049 **Date Collected:** 04/28/2023 06:00 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 49-EL-Room 220

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	3.17	ug/L	15	EPA 200.8	05/11/2023 00:55	

Lab ID: 13968050 **Date Collected:** 04/28/2023 06:00 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 50-EL-Room 221

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	3.31	ug/L	15	EPA 200.8	05/11/2023 00:56	

Lab ID: 13968051 **Date Collected:** 04/28/2023 06:00 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 51-EL-DF near room 218

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 01:07	

Lab ID: 13968052 **Date Collected:** 04/28/2023 06:00 **Matrix:** Potable Water
Sample ID: **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):
Sample Desc: 52-EL-Teachers Workroom Drink Filler

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/11/2023 01:08	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
 www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

		Minnesota Valley Testing Laboratories, Inc. 1126 North Front Street, Building 2 New Ulm, MN 56073 Phone: (507) 354-8517 Toll Free: (800) 782-3557 Fax: (507) 359-2890		Madelia Public School WO: 13968 		Chain of Custody Record Page <u>1</u> of <u>5</u>																																																																																																	
Company Name and Address: Madelia Public School 300 Buck Ave SE Madelia, MN 56042				Work Order # Email: <u>tim-harbo@gmail.com</u>																																																																																																			
Account #: <u>013407</u> Phone #:				Contact (Report to): <u>Tim Harbo</u>																																																																																																			
Billing Address (indicate if different from above):				Name of Samplers: <u>Tim Harbo</u>																																																																																																			
Transferred by:		Date:	Time:	Quote Number	Date Submitted:	Purchase Order #:																																																																																																	
1. <u>Tim Harbo</u>		<u>4/28/23</u>																																																																																																					
2.																																																																																																							
Comments: <u>Am6 CPM 28 APR 23 0735 23.8C TM941</u>				Project Name/Number: <u>Elementary</u>																																																																																																			
<table border="1"> <thead> <tr> <th>Lab Use Only</th> <th>Sample ID</th> <th>Sample Type</th> <th>Date Sampled</th> <th>Time Sampled</th> <th>Number of Bottles</th> <th colspan="2">Analysis</th> </tr> </thead> <tbody> <tr> <td></td> <td>1- EL- Room 103</td> <td>Water</td> <td>4/28/23</td> <td>5:20am</td> <td>1</td> <td colspan="2">Lead</td> </tr> <tr> <td></td> <td>2- EL- Room 104</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td></td> <td>3- EL- Room 105</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td></td> <td>4- EL- DF across from 105</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td></td> <td>5- EL- Room 102</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td></td> <td>6- EL- Room 106</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td></td> <td>7- EL- Room 106 Bathroom</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td></td> <td>8- EL- Room 107</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td></td> <td>9- EL- Room 108</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td></td> <td>10- EL- Room 109</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> <tr> <td></td> <td>11- EL- Room 110</td> <td></td> <td></td> <td></td> <td></td> <td colspan="2"></td> </tr> </tbody> </table>								Lab Use Only	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis			1- EL- Room 103	Water	4/28/23	5:20am	1	Lead			2- EL- Room 104								3- EL- Room 105								4- EL- DF across from 105								5- EL- Room 102								6- EL- Room 106								7- EL- Room 106 Bathroom								8- EL- Room 107								9- EL- Room 108								10- EL- Room 109								11- EL- Room 110						
Lab Use Only	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis																																																																																																	
	1- EL- Room 103	Water	4/28/23	5:20am	1	Lead																																																																																																	
	2- EL- Room 104																																																																																																						
	3- EL- Room 105																																																																																																						
	4- EL- DF across from 105																																																																																																						
	5- EL- Room 102																																																																																																						
	6- EL- Room 106																																																																																																						
	7- EL- Room 106 Bathroom																																																																																																						
	8- EL- Room 107																																																																																																						
	9- EL- Room 108																																																																																																						
	10- EL- Room 109																																																																																																						
	11- EL- Room 110																																																																																																						

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvtl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

		Minnesota Valley Testing Laboratories, Inc. 1126 North Front Street, Building 2 New Ulm, MN 56073 Phone: (507) 354-8517 Toll Free: (800) 782-3557 Fax: (507) 359-2890		Lab Use Only		Chain of Custody Record Page <u>2</u> of <u>5</u>					
Company Name and Address: Madelia Public School 300 Buck Ave SE Madelia, MN 56062		Account #: <u>013407</u> Phone #:				Work Order #			Email: <u>timharbo@gmail.com</u>		
Billing Address (indicate if different from above):		Contact (Report to): <u>Tim Harbo</u>		Name of Samplers: <u>Tim Harbo</u>		Quote Number			Date Submitted:		
Transferred by:		Date:		Time:		Project Name/Number: <u>Elementary</u>			Purchase Order #:		
1. <u>Tim Harbo</u>		<u>4/24/23</u>				Sample Condition:			Received by: <u>Todd Keegan</u>		
2.									Date: <u>28 Apr 23</u> Time: <u>7:35</u> Temp: <u>23.8°C</u>		
Comments:		<u>Amb CM 28 APR 23 0735 23.8C TM 941 TM 941</u>									
Sample Information											
Lab Use Only	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis					
	<u>12-EL-Room 111</u>	<u>Water</u>	<u>4/24/23</u>	<u>5:30</u>	<u>1</u>	<u>Lead</u>					
	<u>13-EL-Room 111 Bathroom</u>										
	<u>14-EL-Media 113 Storage</u>										
	<u>15-EL-Gally Right Sink</u>										
	<u>16-EL-Gally Left Sink</u>										
	<u>17-EL-Cafeteria BF</u>										
	<u>18-EL-Cafeteria DF-Left</u>										
	<u>19-EL-Cafeteria DF-Right</u>										
	<u>20-EL-Kitchen prep sink sprayer</u>										
	<u>21-EL-Kitchen Prep Sink faucet</u>										
	<u>22-EL-Kitch Steam kettle</u>										

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvttl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

		Minnesota Valley Testing Laboratories, Inc. 1126 North Front Street, Building 2 New Ulm, MN 56073 Phone: (507) 354-8517 Toll Free: (800) 782-3557 Fax: (507) 359-2890		Lab Use Only		Chain of Custody Record Page <u>3</u> of <u>5</u>	
Company Name and Address: Madelia Public School 320 Buck Ave SE Madelia, MN 56062		Account #: 013407 Phone #: Billing Address (indicate if different from above):				Work Order #	
Contact (Report to): Tim Harbo		Name of Samplers: Tim Harbo		Quote Number		Date Submitted:	
Project Name/Number: Elementary		Purchase Order #:		Sample Condition:		Received by:	
Transferred by:		Date:		Time:		Date:	
1. Tim Harbo		4/28/23				Todd Hagan 28 Apr 23 7:35 23.8°C	
2.							
Comments: AMB CM 28 APR 23 0735 23.8°C TM 941 TM 941							
Sample Information							
Lab Use Only Lab #	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis	
	23-EL-Nurse Office Sink	Water	4/28/23	5:40	1	Lead	
	24-EL-Nurse Office Bathroom Sink						
	25-EL-Teacher Work Room						
	26-EL-Entry Hall DF-Left						
	27-EL-Entry Hall DF-Right						
	28-EL-Entry Hall BF-Right						
	29-EL-DF across from 119						
	30-EL-Room 119						
	31-EL-Room 121						
	32-EL-Hall by Gym BF						
	33-EL-Gym DE						

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvttl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

		Minnesota Valley Testing Laboratories, Inc. 1126 North Front Street, Building 2 New Ulm, MN 56073 Phone: (507) 354-8517 Toll Free: (800) 782-3557 Fax: (507) 359-2890		Lab Use Only		Chain of Custody Record Page <u>4</u> of <u>5</u>	
Company Name and Address: Madelia Public School 320 Buck Ave SE Madelia, MN 56062		Account #: <u>013407</u> Phone #:				Billing Address (indicate if different from above):	
Contact (Report to): <u>Tim Harto</u>		Name of Samplers: <u>Tim Harto</u>		Quote Number		Date Submitted:	
Project Name/Number: <u>Elementary</u>		Purchase Order #:		Sample Condition:		Received by:	
Transferred by: <u>Tim Harto</u>		Date: <u>4/28/23</u>		Time: <u>7:35</u>		Temp: <u>23.8°C</u>	
Comments: <u>AMBCM 28APR23 0735 23.8C tm 941</u>							
Sample Information							
Lab Use Only Lab #	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis	
	<u>34 - EL - Auditorium Entrance DF</u>	<u>Water</u>	<u>4/28/23</u>	<u>5:50</u>	<u>1</u>	<u>Lead</u>	
	<u>35 - EL - Room 209</u>						
	<u>36 - EL - Room 210</u>						
	<u>37 - EL - Room 211</u>						
	<u>38 - EL - Room 212</u>						
	<u>39 - EL - Room 207</u>						
	<u>40 - EL - Room 213</u>						
	<u>41 - EL - Room 214</u>						
	<u>42 - EL - Room 215</u>						
	<u>43 - EL - Room 216</u>						
	<u>44 - EL - Upper Level BF by Elevator</u>						

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvttl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School

		Minnesota Valley Testing Laboratories, Inc. 1126 North Front Street, Building 2 New Ulm, MN 56073 Phone: (507) 354-8517 Toll Free: (800) 782-3557 Fax: (507) 359-2890		Lab Use Only		Chain of Custody Record Page <u>5</u> of <u>5</u>		
Company Name and Address: Madelia Public School 300 Buck Ave SE Madelia, MN 56262		Account #: 013467 Phone #: Billing Address (indicate if different from above):				Work Order # Email: timothy.horbo@gmail.com		
Transferred by:		Date:	Time:	Quote Number	Date Submitted:		Purchase Order #:	
1. Tim Horbo		4/28/23		Elementary				
2.								
Comments:				Sample Condition:	Received by:	Date:	Time:	Temp:
					Tim Horbo	28 Apr 23	7:35	73.8°C
AMb CM 28 APR 23 0735 73.8°C TM941								
Sample Information								
Lab Use Only Lab #	Sample ID	Sample Type	Date Sampled	Time Sampled	Number of Bottles	Analysis		
	45- EL-Upper level DF by Elevator	Water	4/28/23	6:00	1	Lead		
	46- EL-Room 217-Right Sink							
	47- EL-Room 217-Left Sink							
	48- EL-Room 219							
	49- EL-Room 220							
	50- EL-Room 221							
	51- EL-DF near room 218							
	52- EL-Teachers Workroom Drink Filler							

Enclosed are your containers for your sampling event. Completely fill and label containers appropriately for the analyses to be conducted. Complete chain of custody and submit with samples. For questions regarding individual parameter holding times, chemical and thermal preservation and sample volumes please refer to our sample preservation guide on our website at www.mvttl.com or by contacting customer service at 1-800-782-3557. If samples show signs of contamination, inadequate preservation or are in any way compromised you will be contacted as to whether to proceed with analysis or submit a new sample.

Please submit the top two copies with your samples.

Form # 10-90008-5

See above for page number

Effective Date: 25 Jan 2021

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: Elementary (13968)

Client: Madelia Public School



Sample Condition Checklist

Date: 28 Apr 23 Time: 0735 AM By: CM
Account Name: Madelia Public School-Elem Account #: 013407
Temp: 23.8 C ROI Ambient Tracking #:
TM#: 941 Ice Crystals Present in Sample
MVTL Courier: MVTL Route: Walk-In Mail UPS Air UPS Ground FedEx Air Fed Ex Ground SpeeDee
Containers Supplied by MVTL: Yes No Designate customer supplied containers as "Other" in container size column

Table with columns: Number, Containers Size (mL), Container Type, Preservation, pH. Includes rows for various container sizes and types, and a section for Low Level Mercury Kit.

*ANY CONTAINER SENT TO A SUBCONTRACT LABORATORY WILL NOT BE CHECKED FOR PRESERVATION!

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 11, 2023 4:36:20 PM