



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: High School (13965)

Client: Madelia Public School

Account #: 13407

Tim Harbo
Madelia Public School
320 Buck Ave SE
Madelia, MN 56062

Certificate of Analysis

Approval

All data reported has been reviewed and approved by:

Dave Smahel, Inorganic Chemistry/Feed Lab Manager New Ulm, MN

Analyses performed under Minnesota Department of Health Accreditation conforms to the current TNI standards.

NEW ULM LAB CERTIFICATIONS:
MN LAB # 027-015-125ND WW/DW # R-040

BISMARCK LAB CERTIFICATIONS:
MN LAB # 038-999-267ND W/DW # ND-016

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 18, 2023 5:43:38 PM

Page 1 of 7



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: High School (13965)

Client: Madelia Public School

Workorder Summary

Workorder Comments

All samples were preserved with nitric acid upon receipt at the laboratory.

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 18, 2023 5:43:38 PM

Page 2 of 7



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: High School (13965)

Client: Madelia Public School

Analytical Results

Lab ID: 13965001 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 1-HS-BF wrestling room **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:11	

Lab ID: 13965002 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 2-HS-DF wrestling room **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:12	

Lab ID: 13965003 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 3-HS-Lower Level BF North **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:13	

Lab ID: 13965004 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 4-HS-Lower Level DF North **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:14	

Lab ID: 13965005 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 5-AS-Kitchen Sprayer **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:23	

Lab ID: 13965006 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 6-HS-Kitchen Kettle **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
-----------	---------	-------	-----	--------	----------	------

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: [Thursday, May 18, 2023 5:43:38 PM](#)



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: High School (13965)

Client: Madelia Public School

Analytical Results

Lead 5.01 ug/L 15 EPA 200.8 05/17/2023 15:24

Lab ID: 13965007 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 7-HS-FACS #1 **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.97	ug/L	15	EPA 200.8	05/17/2023 15:25	

Lab ID: 13965008 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 8-HS-FACS #2 **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.00	ug/L	15	EPA 200.8	05/17/2023 15:26	

Lab ID: 13965009 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 9-HS-FACS #3 **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.38	ug/L	15	EPA 200.8	05/17/2023 15:27	

Lab ID: 13965010 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 10-HS-FACS #4 **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.55	ug/L	15	EPA 200.8	05/17/2023 15:28	

Lab ID: 13965011 **Date Collected:** 04/28/2023 06:15 **Matrix:** Potable Water
Sample ID: 11-HS-FACS #5 **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:29	

Lab ID: 13965012 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 12-HS-Room 119 (S) **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	227	ug/L	15	EPA 200.8	05/17/2023 15:38	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 18, 2023 5:43:38 PM

**MINNESOTA VALLEY TESTING LABORATORIES, INC.**

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
 2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
 1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
 www.MVTL.com

**Workorder:** High School (13965)**Client:** Madelia Public School**Analytical Results**

Lab ID: 13965013 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 13-HS-Lower Level
 BF South **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:31	

Lab ID: 13965014 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 14-HS-Lower Level
 DF South **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:32	

Lab ID: 13965015 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 15-HS-Upper Level
 BF South **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:44	

Lab ID: 13965016 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 16-HS-Upper Level
 DF South **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:45	

Lab ID: 13965017 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 17-HS-Office
 Restroom **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	1.76	ug/L	15	EPA 200.8	05/17/2023 15:46	

Lab ID: 13965018 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 18-HS-Upper level
 BF North **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 18, 2023 5:43:38 PM



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: High School (13965)

Client: Madelia Public School

Analytical Results

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:47	

Lab ID: 13965019 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 19-HS Upper Level DF North **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:48	

Lab ID: 13965020 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 20-HS-Room 205 right most **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Sample Desc: faucet

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	2.59	ug/L	15	EPA 200.8	05/17/2023 15:49	

Lab ID: 13965021 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 21-HS-Room 205 left drink tap **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:50	

Lab ID: 13965022 **Date Collected:** 04/28/2023 06:25 **Matrix:** Potable Water
Sample ID: 22-HS Room 205 Center Tap **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	0.87	ug/L	15	EPA 200.8	05/17/2023 15:51	

Lab ID: 13965023 **Date Collected:** 04/28/2023 06:35 **Matrix:** Potable Water
Sample ID: 23-HS-Gym BF West **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:52	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.



MINNESOTA VALLEY TESTING LABORATORIES, INC.

1126 North Front St. ~ New Ulm, MN 56073 ~ 800-782-3557 ~ Fax 507-359-2890
2616 East Broadway Ave. ~ Bismarck, ND 58501 ~ 800-279-6885 ~ Fax 701-258-9724
1201 Lincoln Hwy. ~ Nevada, IA 50201 ~ 800-362-0855 ~ Fax 515-382-3885
www.MVTL.com



Workorder: High School (13965)

Client: Madelia Public School

Analytical Results

Lab ID: 13965024 **Date Collected:** 04/28/2023 06:35 **Matrix:** Potable Water
Sample ID: 24-HS-Gym DF West **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 15:53	

Lab ID: 13965025 **Date Collected:** 04/28/2023 06:35 **Matrix:** Potable Water
Sample ID: 25-HS Gym DF East **Date Received:** 04/28/2023 07:35
Temp @ Receipt (C):

Parameter	Results	Units	MCL	Method	Analyzed	Qual
Lead	<0.5	ug/L	15	EPA 200.8	05/17/2023 16:06	

MVTL guarantees the accuracy of the analysis done on the sample submitted for testing. It is not possible for MVTL to guarantee that a test result obtained on a particular sample will be the same on any other sample unless all conditions affecting the sample are the same, including sampling by MVTL. As a mutual protection to clients, the public and ourselves, all reports are submitted as the confidential property of clients, and authorization for publication of statements, conclusions or extracts from or regarding our reports is reserved pending our written approval.

Report Date: Thursday, May 18, 2023 5:43:38 PM